

**John Murray**Bos Meeting  
09-10-07

---

**From:** Doug Halley  
**Sent:** Monday, September 10, 2007 3:52 PM  
**To:** John Murray  
**Subject:** 4 High Street

You asked a question regarding the potential for 4 High Street if an on-site system was utilized instead of a connection to the sewer system. Based on the existing septic system, the types of soils and the developmental requirements of the site the Health Department would estimate that approximately three 3-bedroom units could be serviced by an on-site system. However, depending on how those units are structured and what additional soil tests might show that estimate could either increase or decrease by a 25% to 50% margin.

9/10/2007